

**DEPARTMENT OF HEALTH & HUMAN SERVICES**

Public Health Service  
Food and Drug Administration

Refer to: CFN 1130162

Baltimore District  
900 Madison Avenue  
Baltimore, Maryland 21201  
Telephone: (410) 962-4012

April 10, 1998

**WARNING LETTER****CERTIFIED MAIL**  
**RETURN RECEIPT REQUESTED**

Mr. Steven Boykin, Station Manager  
U.S. Airways  
Baltimore-Washington International Airport  
Baltimore, Maryland 21240

Dear Mr. Boykin:

On April 7, 1998, a representative of the Food and Drug Administration conducted an inspection of your servicing facility at the Baltimore-Washington International Airport, Baltimore, Maryland. This inspection was conducted under the authority of the Public Health Service Act and the Federal Food, Drug, and Cosmetic Act. The inspectional findings were listed on form FDA-483 (List of Observations) and discussed with Mr. Thomas Hay, Maintenance Manager. A copy of the FDA-483 is enclosed for your reference.

The inspection revealed significant deviations from the Interstate Conveyance Regulations [21 CFR 1250], as follows:

- Lavatory truck (#SF071) was leaking sewage and sanitizer.
- Ice machine (unit #1) had exposed wiring and the temperature probe was in contact with the ice.
- Potable water truck (#56032) was leaking water.

As a result of these deficiencies, this facility has been classified as "Provisional." A reinspection will be conducted on or about May 7, 1998, to determine if future classification

Mr. Steven Boykin

Page 2

April 10, 1998

will be "Approved" or "Not Approved." A "Not Approved" classification means you cannot provide water/sewage service to airlines.

Please advise this office in writing, within 15 working days of receipt of this letter, regarding actions taken to correct the deficiencies and to assure that such violative conditions will not recur.

Your response should be directed to Wiley T. Williamson, III, Compliance Officer, Food and Drug Administration, 900 Madison Avenue, Baltimore, Maryland 21201. Mr. Williamson can be reached at 410-962-4366, Extension 136.

Sincerely,

  
WILLIAM M. MENT  
Acting District Director

Enclosure